



BASE PRICING:

FDC - 8300	\$275.00
FDC - 4300	\$325.00

(1/8 DIN)	FDC - 8300
(1/4 DIN)	FDC - 4300

1	2	3	4	5	6	7	8	9	

Schedule A

1. POWER INPUT

4:	90-264VAC 50/60 HZ	N/C
5:	11-26VAC/VDC	\$15.00
9:	Special Order	

2. SIGNAL INPUT

1:	Input 1 - Universal T/C, RTD or 4/20, 0-20 mA 0-1V, 0-5V, 1-5V, 0-10VDC	N/C
	Input 2—CT and Analog input * 4-20, 0-20 mA, 0-1V, 0-5V, 1-5V, 0-10VDC CT: 0-50 Amp AC current transformer	N/C
	Input 3—Event Input	N/C
9:	Special Order	

3. OUTPUT 1

0:	None	N/C
1:	Form A Relay 2A/240VAC resistive (N.O.)	N/C
2:	SSR Drive 5VDC @30 mA	N/C
3:	4-20/0-20 mA linear, isolated, max load 500 ohms	\$26.00
4:	1-5/0-5VDC linear, isolated, min impedance 10K ohms	\$26.00
5:	0-10VDC linear, isolated, min impedance 10K ohms	\$26.00
6:	Triac 1A/240VAC	\$26.00
C:	SSR Drive 14VDC @40 mA	\$26.00
9:	Special Order	

4. OUTPUT 2 (control PID Cool only)

0:	None	N/C
1:	Form A Relay 2A/240VAC resistive (N.O.)	\$11.00
2:	SSR Drive 5VDC @30 mA	\$11.00
3:	4-20/0-20 mA linear, isolated, max load 500 ohms	\$26.00
4:	1-5/0-5VDC linear, isolated, min impedance 10K ohms	\$26.00
5:	0-10VDC linear, isolated, min impedance 10K ohms	\$26.00
6:	Triac 1A/240VAC	\$26.00
7:	Transmitter Power Supply 20VDC/25 mA (isolated)	\$26.00
8:	Transmitter Power Supply 12VDC/40 mA (isolated)	\$26.00
9:	Transmitter Power Supply 5VDC/80 mA (isolated)	\$26.00
C:	SSR Drive 14VDC @40 mA	\$26.00
A:	Special Order	

5. ALARM 1

0:	None	N/C
1:	Form C Relay 2A/240VAC resistive***	\$11.00
9:	Special Order	

6. ALARM 2

0:	None	N/C
1:	Form A Relay 2A/240VAC resistive (N.O.)	\$11.00
9:	Special Order	

7. COMMUNICATIONS

0:	NONE	N/C
1:	RS-485 Modbus RTU	\$70.00
2:	RS-232 Modbus RTU	\$70.00
3:	Retransmission: 0-20/4-20 mA, isolated, 500 ohm load min	\$80.00
4:	Retransmission: 0-5/1-5 VDC, isolated, 10K ohm load min	\$80.00
5:	Retransmission: 0-10 VDC, isolated, 10K ohm load min	\$80.00
9:	Special Order	

8. ENCLOSURE OPTIONS

0:	IP50 Standard	N/A
1:	IP65 (Nema 4X)	\$10.00

9. SPECIAL ORDER

Leave Blank unless assigned a specific 2-character
 Special Order Code

Note: The last digit (codes 9) is typically left blank

* Order CT94-1 if heater break function is required.
 Output 2: Configurable for PID cool (requires output #1 to be PID):
 PID cool outputs: Relay, SSR or mA/VDC.



File#: E197216



209463

RoHS Compliant

P.O. Box 1196 · Bridgeview, IL 60455
 888.751.5444 Sales · 888.307.8014 Fax

Technical Support: 866.342.5332
<http://www.futuredesigncontrols.com>